



ACCESSORIES				
MK	SIZE	DESCRIPTION	DEG	ELEV / DOME
-	-	-	-	-

- NOTES:
- 1 LOCATE FITTINGS FROM PLAN VIEW.
  - 2 TANK(S) MUST BE INSTALLED PER ASSMANN CORPORATION USAGE & GUIDELINES.
  - 3 FLEXIBLE EXPANSION JOINTS MUST BE USED ON ALL SIDEWALL CONNECTIONS.
  - 4 TANKS ARE BUILT PER ASTM D 1998.

- NOTES:
- 1 LOWER FLATS 11' W X 12' H (4 PLACES)
  - 2 MOLDED IN TIE DOWN (4 PLACES)
  - 3 MOLDED IN VOLUME MARKER
  - 4 16" MANWAY WITH LEVER LOCK COVER

REV	REVISION DESCRIPTION	REV DATE

  

		300 N TAYLOR ROAD GARRETT, IN 46738 PHONE: (260) 357-3181 FAX: (260) 357-9738	
TITLE: ICN 1550 GALLON VERTICAL STORAGE TANK		RESIN USED: POLYETHYLENE SP.G. MAX	
DRAWN BY: SKRWLISON	DRAWN DATE: 11/21/11	SALES ORDER#	TANK WEIGHT: LBS.
TANK DIVG NUMBER: ICTN1550		TANK REV:	

ALL DIMENSIONS ARE IN INCHES AND ARE ±3%