



ACCESSORIES					
MK	SIZE	DESCRIPTION	DEG	ELEV	DOME

- NOTES:
 1 7' ACCESS W/ THREADED LID
 2 MOLDED IN PUMP SHELF
 3 PRIMARY CALCULATED GALLONS PER INCH: 3.06 GPI
 4 SECONDARY CALCULATED GALLONS PER INCH: 3.93 GPI

C	TURNED THE TANK 180° SO THE ACCESS IS AT 0°	06/12/08	MG
B	CORRECTED SHELF SIZE / CORRECTED RAISE PORTION AROUND LID	2/6/04	dcm
A	ADDED FITTING FLAT TO LOW SIDEWALL	2/6/04	dcm
REV	REVISION DESCRIPTION	REV DATE	

		300 N TAYLOR ROAD GARRETT, IN 46738 PHONE: (260) 357-3181 FAX: (260) 357-9728		CUSTOMER APPROVAL _____ DATE: _____	
PRIMARY VESSEL POLYETHYLENE RESIN USED: _____ TANK GRAVITY: _____ TANK WEIGHT: _____	SECONDARY VESSEL POLYETHYLENE RESIN USED: _____ TANK GRAVITY: _____ TANK WEIGHT: _____	SP.G. MAX - LBS.	SP.G. MAX - LBS.	DRAWN BY J. MYERS	DRAWN DATE 10/22/03
TITLE: IMT 85 GAL. DOUBLE WALL STORAGE TANK				ASSMANN CORPORATION DWG NUMBER: IMT 85 C	
ALL DIMENSIONS ARE IN INCHES AND ARE ±3%					